

| SSO Notification List | | | | | | | | | | | | |
|-----------------------|--------------------|-------------------------|----------|-----------------------------------|-----------------|--------------------|----------------------------------|------------------------------------|--------------------------------------|--|--|--------------|
| April 2010 | | | | | | | | | | | | |
| Serial No. | Date of Occurrence | Location | Zip Code | Reason | Stream Affected | Duration (Hrs:Min) | Time | Description of Discharge | Est. Quantity of Discharge (gallons) | Measures taken to Minimize Discharge | Preventive Action to Stop Recurrence | Work Order # |
| 1 | 4/3/2010 | 1821 St Paul St | 21202 | Rags | Jones Falls | 2:35 | 7:25 AM - 10:00 AM | Rags & Grease | Evidence of Overflow | Relieved M/L Choke with Pressure Truck | Turned over to be CCTV'ed & Regular Flushing of Line | 107647 |
| 2 | 4/5/2010 | 108 Hawthorne Road | 21210 | Rags & Roots | Gwynns Falls | 3:00 | 10:20 PM - 1:20 PM | Heavy Gray Water | 360 | Relieved M/L Choke with Pressure Truck | Turned over to be CCTV'ed | 107706 |
| 3 | 4/5/2010 | 2800 Rosalind Ave | 21215 | Rags & Grease | Gwynns Falls | 4:14 | 5:11 PM - 9:25 PM | Sewer Water, Paper Debris & Grease | 1,270 | Relieved M/L Choke with Pressure Jet | Turned over to be CCTV'ed | 107740 |
| 4 | 4/5/2010 | 900 N Payson Ave | 21217 | Rags & Grease | Gwynns Falls | 0:58 | 10:47 PM - 11:45 PM | Sewer Water | 580 | Relieved M/L Choke with Pressure Jet | Turned over to be CCTV'ed | 107748 |
| 5 | 4/5/2010 | 403 Old Orchard Road | 21229 | Rags, Grease, Sand Gravel & Rocks | Gwynns Falls | 20:00 | 4/5/10 6:00 PM to 2:00 PM 4/6/10 | Heavy Gray Water | 3,600 | M/L Broke due to BGE Pole Hitting Line | By-pass Pumping - Construction made Repairs | 107734 |
| 6 | 4/8/2010 | 234 McMachen Street | 21217 | Debris & Grease | Jones Falls | 2:05 | 5:55 PM - 8:00 PM | Sewer Water | 1,875 | Relieved M/L Choke with Pressure Jet | Turned over to be CCTV'ed | 107884 |
| 7 | 4/11/2010 | 2433 Washington Blvd | 21230 | Rags, Grease, Sand Gravel & Rocks | Gwynns Falls | 1:00 | 5:15 PM - 6:15 PM | Heavy Gray Water | 180 | Relieved M/L Choke with Pressure Truck | Line to be TV'ed | 107921 |
| 8 | 4/11/2010 | 4800 Falls Road | 21210 | Rags & Roots | Jones Falls | 1:00 | 1:00 PM - 2:00 PM | Heavy Gray Water | 120 | Relieved M/L Choke with Pressure Truck | Line to be TV'ed | 107965 |
| 9 | 4/11/2010 | 206 Edgevale Road | 21210 | Rags & Roots | Jones Falls | 1:00 | 12:31 PM - 1:31 PM | Heavy Gray Water | 120 | Relieved M/L Choke with Pressure Truck | Turned over to be CCTV'ed | 107964 |
| 10 | 4/12/2010 | 100 Indian Lane | 21210 | Roots | Jones Falls | 2:00 | 11:20 AM - 1:20 PM | Heavy Gray Water | 600 | Relieved M/L Choke with Pressure Truck | Turned over to be CCTV'ed | 107908 |
| 11 | 4/12/2010 | 1600 Morris Road | 21216 | Rags, Grease, Sand Gravel & Rocks | Gwynns Falls | 3:14 | 8:46 AM - 12:00 PM | Heavy Gray Water | 388 | Relieved M/L Choke with Pressure Truck | Turned over to be CCTV'ed | 107984 |
| 12 | 4/13/2010 | 1000 Park Ave | 21201 | Rags & Roots | Jones Falls | 3:00 | 8:26 AM - 11:26 AM | Heavy Gray Water | 900 | Relieved M/L Choke with Pressure Truck | Turned over to be CCTV'ed | 108021 |
| 13 | 4/14/2010 | 2325 Hollins Ferry Road | 21230 | Rags & Grease | Gwynns Falls | 5:17 | 5:43 AM - 11:00 AM | Heavy Gray Water | 3,170 | Relieved M/L Choke with Pressure Truck | Turned over to be CCTV'ed | 108053 |
| 14 | 4/14/2010 | 1900 Ashburton Street | 21216 | Grease & Debris | Gwynns Falls | 1:28 | 5:16 PM - 6:44 PM | Sewer Water | 440 | Relieved M/L Choke with Pressure Truck | Turned over to be CCTV'ed | 108073 |
| 15 | 4/16/2010 | 1325 Key Highway | 21230 | Grease | Inner Harbor | 1:51 | 7:59 PM - 9:50 PM | Sewer Water & Grease | 1,110 | Relieved M/L Choke with Pressure Truck | Turned over to be CCTV'ed | 108161 |

| Serial No. | Date of Occurrence | Location | Zip Code | Reason | Stream Affected | Duration (Hrs:Min) | Time | Description of Discharge | Est. Quantity of Discharge (gallons) | Measures taken to Minimize Discharge | Preventive Action to Stop Recurrence | Work Order # |
|------------|--------------------|-------------------------|----------|-----------------------|-----------------|--------------------|---------------------|--------------------------|--------------------------------------|--|--------------------------------------|--------------|
| 16 | 4/19/2010 | 3205 Pinkey Road | 21215 | Rags & Roots | Jones Falls | 3:00 | 8:37 AM - 11:37 AM | Heavy Gray Water | 540 | Relieved M/L Choke with Pressure Truck | Turned over to be CCTV'ed | 108208 |
| 17 | 4/27/2010 | 5709 Chinquapin Parkway | 21239 | Rags, Grease & Debris | Herring Run | 1:11 | 10:19 AM - 11:30 AM | Sewer Water | 355 | Relieved M/L Choke with Pressure Jet | Turned over to be CCTV'ed | 108574 |
| 18 | 4/29/2010 | 1861 N. Gay Street | 21213 | Rags | Inner Harbor | 1:30 | 9:15 AM - 10:45 AM | Gray Water | 450 | Relieved M/L Choke with Pressure Jet | Turned over to be CCTV'ed | 108636 |
| | | | | | | | | TOTAL | 16,058 | | | |